

VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)
WATER BACTERIOLOGY RESULTS

LITS Number 2006051760-001-A

State Health Dept No.08WB04087

Kit Type Kit AA Coliform (Regulated Systems)

WSID# 0000005096

Kit Number 9608701

Report To
MARC MAHEUX
JERICHO-UNDERHILL WATER
32 POKER HILL RD
PO BX 236
UNDERHILL VT 05489

Public Water System Only

JERICHO-UNDERHILL WATER

Sampler Title OPERATOR
Purpose of Sample Routine
Type of Sample Distribution
Chlorine, free
Chlorine, total
Field Temp (C)
Action Limit

Date/Time Received 10/11/2007 10:03:00

Date/Time of Collection 10/11/2007 09:30:00

Town Jericho

Collected By MARC MAHEUX

Sample Location 100 RACEWAY RD/KITCHEN/DOWNST.

Date Analyzed 10/12/2007

Field Sample Number

Report Status Final

Date Reported 10/12/2007

Released by KBW

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

The water sample tested is bacteriologically suitable for drinking (potable). IMPORTANT: Bacteriological testing of a single sample of water is only one means of determining the suitability of water for drinking. It is also critical that the water source location, system construction and ongoing maintenance/treatment are adequate to consistently protect against bacterial contamination.

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 10/12/2007 11:46:45