



# EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077  
Phone/Fax: (800) 220-3675 / (856) 786-5974  
<http://www.EMSL.com> / [cinnasblab@EMSL.com](mailto:cinnasblab@EMSL.com)

EMSL Order ID: 041620625  
Customer ID: MISC-SC  
Customer PO: Marc  
Project ID:

**Attn:** Marc Mahuex

PO Box 174  
Underhill, VT 05489

Phone: (802) 899-3810

Fax:  
Collected: 07/27/2016  
Received: 07/28/2016  
Analyzed: 08/09/2016

**Proj:** Jericho Underhill Water District / Asbestos Count

## Test Report: Determination of Asbestos Structures > 10µm in Water Performed by the 100.2 Method (EPA 600/R-94/134)

### ASBESTOS

| Sample ID<br>Client / EMSL | Sample<br>Filtration<br>Date/Time | Original<br>Sample Vol.<br>Filtered<br>(ml) | Effective<br>Filter<br>Area<br>(mm <sup>2</sup> ) | Area<br>Analyzed<br>(mm <sup>2</sup> ) | Asbestos<br>Types | Fibers<br>Detected | Analytical<br>Sensitivity | Concentration                  | Confidence<br>Limits |
|----------------------------|-----------------------------------|---|---|--|-------------------|--------------------|---------------------------|--------------------------------|----------------------|
|                            |                                   |   |   |  |                   |                    |                           | MFL (million fibers per liter) |                      |
| 01<br>041620625-0001       | 7/28/2016<br>08:45 AM             | 100   | 1392  | 0.0792                                 | None Detected     | ND                 | 0.18                      | <0.18                          | 0.00 - 0.65          |

VT ID: TB538221

Analyst(s)

Peter Harrison (1)

Benjamin Ellis, Laboratory Manager  
or Other Approved Signatory

Any questions please contact Benjamin Ellis.

Initial report from: 08/09/2016 14:17:06

Sample collection and containers provided by the client, acceptable bottle blank level is defined as  $\leq 0.01$  MFL > 10µm. ND=None Detected. This report may not be reproduced, except in full, without written permission by EMSL Analytical, Inc. The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to the samples reported above. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NELAC NJ DEP 03036, PA ID# 68-00367