

Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.32, Record generated: 4/10/2026 4:35:04 PM

Submission #: HQM-Q7WS-H6N7G, version 1

Details

Submitted: 4/10/2026 4:26:48 PM by Lane Simon

ID: VT0005096 2026 March

Submission ID: HQM-Q7WS-H6N7G

Form Input

Water System Information

Water System ID

VT0005096

Name of Water System

JERICO UNDERHILL WATER

Report Year

2026

Month Being Reported (the month the report represents, not the current month)

March

Any notes to share

Is a master meter which measures total water production of the system installed and functioning?

Yes

Meter Readings and Usage

Select how your usage is reported

Gallons

Meter reading on last day of previous month

0

Meter reading on last day of reporting month

0

Total Water Production for the Reporting Period

1172155

Displayed below is your usage (in gallons) for the most recent period for which you submitted a report. This is provided for informational purposes only.

Prior Report Total Water Production

1033345

Continuous Monitoring of Free Chlorine Residuals

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

Did continuous monitoring fail at any time this month?

No

Are you submitting a daily detail table?

Yes

Daily Data Detail Table (1 of 1)

Facility

TP001 - TREATMENT PLANT 1

Did the facility utilize standby chlorination at any point during this reporting period

Yes

Are you writing down the numbers from the meter display or are you calculating the amount of water produced each day?

Recording the meter each day

Does the meter report in gallons or cubic feet?

Gallons

Daily Reporting Data

Day	Meter or Gallons	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
03/01/2026	26571	0.963			
03/02/2026	46502	0.958	70		0.95
03/03/2026	51130	0.964			
03/04/2026	29757	0.957	0.97		0.91
03/05/2026	29637	0.964			
03/06/2026	31778	0.872	0.84		0.8
03/07/2026	57614	0.81			
03/08/2026	36478	0.809			

03/09/2026	35031	0.808	0.8		1.1
03/10/2026	33633	0.811			
03/11/2026	33096	0.806	0.87		1.42
03/12/2026	35505	0.805			
03/13/2026	34968	0.803	0.95		1.21
03/14/2026	37149	0.801			
03/15/2026	36739	0.809			
03/16/2026	36834	0.802	0.81		0.88
03/17/2026	35431	0.811			
03/18/2026	55679	0.805	1.03		1.03
03/19/2026	40417	0.801	0.98		0.88
03/20/2026	33111	0.805			
03/21/2026	33766	0.804	1.01		1.09
03/22/2026	34281	0.802			
03/23/2026	31597	0.805	1.06		1.17
03/24/2026	64720	0.809	0.83		0.82
03/25/2026	34525	0.8			
03/26/2026	36528	0.802	0.96		1.18
03/27/2026	37212	0.8			
03/28/2026	35410	0.801	0.82		1.51
03/29/2026	34217	0.799			
03/30/2026	38919	0.8	1.18		1.21
03/31/2026	33920	0.802			