



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

December 11, 2003

Marc Mahaux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc
Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
10/31/03	1.1	1.1
11/07/03	1.0	1.1
11/14/03	1.0	1.0
11/21/03	1.1	1.0
11/28/03	1.1	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund
Alida I. Lund
Fluoridation Technician