



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

July 13, 2005

mae makew
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

mae
Dear Mrs. ~~Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
03/18/05	1.0	0.5
03/25/05	0.8	0.4
04/01/05	0.7	0.3
04/08/05	0.7	0.3
04/15/05	0.5	0.2
04/22/05	0.5	0.2
04/29/05	0.6	0.2
05/06/05	0.5	0.9
05/13/05	1.1	0.9
05/20/05	1.1	0.8
05/27/05	1.2	1.0
06/03/05	1.2	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

July 14, 2005

Helen Miller
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear Mrs. Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
06/10/05	1.3	0.9
06/17/05	1.2	1.0
07/01/05	1.2	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund
Fluoridation Technician

