

# Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.20, Record generated: 2/9/2024 8:35:10 AM

**Submission #:** HQ1-9DC3-TRJQ3, version 1

## Details

---

**Submitted:** 2/9/2024 7:45:47 AM by Lane Simon

**ID:** VT0005096 January

**Submission ID:** HQ1-9DC3-TRJQ3

## Form Input

---

### Water System Information

**Water System ID**

VT0005096

**Name of Water System**

JERICO UNDERHILL WATER

**Month Being Reported (the month the report represents, not the current month)**

January

**Report Year**

2024

**Any notes to share**

**Is a master meter which measures total water production of the system installed and functioning?**

Yes

**Meter Readings and Usage**

---

**Select how your usage is reported**

Gallons

**Meter reading on last day of previous month**

0

**Meter reading on last day of reporting month**

0

**Total Water Production for the Reporting Period**

1210426

Displayed below is your usage (in gallons) for the most recent period for which you submitted a report. This is provided for informational purposes only.

**Prior Report Total Water Production**

1254928

**Continuous Monitoring of Free Chlorine Residuals**

---

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

**Did continuous monitoring fail at any time this month?**

No

**Are you submitting a daily detail table?**

Yes

**Daily Data Detail Table (1 of 1)**

---

**Facility**

TP001 - TREATMENT PLANT 1

**Did the facility utilize standby chlorination at any point during this reporting period**

Yes

**Are you reporting daily meter readings or daily gallons produced?**

Gallons produced

**Daily Reporting Data**

Day	Meter or Gallons	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
01/01/2024	37788	0.109	0.9		1.55
01/02/2024	37403	0.143	0.8		
01/03/2024	62578	0.127	0.9		1.02
01/04/2024	38733	0.152	0.9		
01/05/2024	35622	0.135	1		0.77
01/06/2024	34183	0.135	0.9		
01/07/2024	38336	0.035	0.9		
01/08/2024	35516	0.082	1		1.07
01/09/2024	37018	0.145	1		
01/10/2024	33672	0.122	0.9		1.11
01/11/2024	37422	0.14	1		

01/12/2024	66068	0.13	1		0.99
01/13/2024	34738	0.112	0.8		
01/14/2024	35769	0.13	0.9		
01/15/2024	34647	0.132	1		1.15
01/16/2024	35224	0.129	0.9		
01/17/2024	33769	0.114	1		1.03
01/18/2024	35256	0.126	1		1.73
01/19/2024	54214	0.115	1		
01/20/2024	42793	0.136	0.9		
01/21/2024	36278	0.129	0.8		
01/22/2024	33225	0.135	1		1.51
01/23/2024	34241	0.134	1		
01/24/2024	33079	0.105	1		
01/25/2024	36593	0.015	1		1.24
01/26/2024	63377	0.118	1		1.06
01/27/2024	34410	0.159	0.7		
01/28/2024	36820	0.148	0.9		
01/29/2024	33235	0.152	1.1		1.06
01/30/2024	34476	0.151	0.9		
01/31/2024	34892	0.121	0.9		0.77