VERMONT
DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # :	**18-IC-01252**
Report Status :	**Final**
Date Report Released :	**07/06/2018**

Report To	Jericho Underhill Water	**WSID**	VT0005096
ATTN OF	Marc Maheux	**Account Name**	Jericho Underhill Water
Address	PO Box 174	**Date Received**	06/29/2018
		Time Received	08:10
	Underhill, VT 05489	**Approved Date**	07/06/2018

Sample Desc.	Munic Fl	**Sample Type**	Routine/Comp
Collection Date	06/27/2018	**Collection Type**	
Collection Time	07:45	**Free Chlorine Residual**	
Sampled By	Helen Miller	**Total Chlorine Residual**	
Sampling Location	Kitchen Sink	**Chlorinated?**	
Street Address	406 Vt Rt 15	**Field Temp.**	
Town	Underhill	**Field Fluoride**	1.0 mg/L
Sampler's Comments		**Temp at Receipt**	

Test ***Fluoride***

Date/Time of Analysis 07/05/2018 13:58
Test Method LACHAT 10-109-12-2-A

Analyte	Final Result	Units	Limit
Fluoride	0.7	mg/L	4.0 MCL

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: Mary Celotti

Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report, please call the laboratory at (802) 338-4724