

VERMONT MONTHLY WATER SYSTEM OPERATIONS REPORT
FOR GROUND WATER SOURCES
AND
SYSTEMS PURCHASING WATER FOR RESALE

Reporting for the month of November 20 00

Name of Water System: JERICO UNDERHILL WATER DISTRICT

WSID * 5096 Town: Underhill

Operator Name: MARC MAHEUX Phone (Work): 899-2981

Please provide the following information".

1. Is a master meter which measures total water production of the system installed and functioning?
 [YES] [NO] (Please circle one)

If [YES], please complete Items 2-6; if [NO], skip to Item 5

- | | | |
|--|----------|---------|
| 2. Meter reading on LAST day of Reporting month: | 97108500 | Gallons |
| 3. Meter Reading on LAST day of Previous month: | 95782400 | Gallons |
| 4. Difference in Readings (Total Production) : | 1326100 | Gallons |

5. Have the results of all water quality compliance analyses performed during this month been submitted to the Water Supply Division? [YES] [No] (Please circle one)

(if NO, please submit a copy of all results with this monthly report.)

Only samples submitted to the Vermont Department of Health Laboratory in Burlington are reported to the state automatically. All other sample results, such as from private laboratories, must be submitted by you with this report. All compliance samples must be analyzed by a laboratory certified by the State of Vermont to analyze for the specific constituent.

6. If you disinfect/chlorinate or fluoridate your water on any day of this monthly report, or if your operating permit requires that you report daily values for flow (or other), you must also complete the reverse side of this form.

I certify, as the responsible person of this water system, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure that the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.



12/1/00

Marc Maheux

Signature

Date

Please Type or Print Name

"Responsible Person means the owner, co-op president, elected or appointed official, or other person with general management, financial, operational and maintenance responsibilities for a water system."

Please submit this form within ten (10) days after the end of the month to:

Water Supply Division
Attn: Laura Lafleur
103 So. Main St.
Waterbury, VT 05671-0403

Please check here
if you need more forms

VERMONT MONTHLY WATER SYSTEM OPERATIONS REPORT

SUPPLEMENTAL INFORMATION

For the month of - November 2000

NOTE: This Side of The Form Must be Completed if You:

- 1) Disinfect/chlorinate your water on any day(s) of the month. (Column 2)
- 2) Fluoridate your water. Daily values are required by Rule. (Column 3)
- 3) Are required by your Operating Permit to report daily values.

Day of the Month	Water Production	Disinfection/Chlorination (Free CL, in mg/l)	Fluoride (mg/l)	Other (Describe)
	(Column 1) Metered Values (Gallons/Day)	(Column 2) Dist. System Residual Analysis	(Column 3) Entering Distribution System	(Column 4) PO ₄
1	48014	.1	1.2	1.29 32 Pokerhill
2	48014	.1	1.2	1.29 32 Pokerhill
3	48014	.1	1.2 #221	1.29 32 Pokerhill
4	48014	.1	1.2	1.29 32 Pokerhill
5	48014	.2	1.2	1.29 32 Pokerhill
6	48014	.1	1.0	1.29 32 Pokerhill
7	48014	.1	1.3	1.29 32 Pokerhill
8	46186	.1	1.2	1.29 32 Pokerhill
9	46186	.1	1.3	.64 Control Building
10	46186	.1	1.3 #222	.64 Control Building
11	46186	.1	1.2	.64 Control Building
12	46186	.1	1.1	.64 Control Building
13	46186	.2	1.2	.64 Control Building
14	46186	.1	1.1	.64 Control Building
15	42814	.1	1.2	.64 Control Building
16	42814	.1	1.2	1.29 32 Pokerhill
17	42814	.1	1.2 #223	1.29 32 Pokerhill
18	42814	.1	1.3	1.29 32 Pokerhill
19	42814	.1	1.2	1.29 32 Pokerhill
20	42814	.1	1.2	1.29 32 Pokerhill
21	42814	.1	1.1	1.29 32 Pokerhill
22	40086	.1	1.2	1.29 32 Pokerhill
23	40086	.2	1.2	.76 Control Building
24	40086	.2	1.2 #224	.76 Control Building
25	40086	.2	1.2	.76 Control Building
26	40086	.1	1.2	.76 Control Building
27	40086	.1	1.2	.76 Control Building
28	40086	.1	1.2	.76 Control Building
29	43200	.1	1.2	.76 Control Building
30	43200	.1	1.2	.76 Control Building
31	N/A	N/A	N/A	N/A
Totals	1326100	N/A	N/A	N/A

Questions? Please Call 1-800-823-6500