



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

June 21, 2002

Marc Maheux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc
Dear Mrs. ~~Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

| DATE | FIELD RESULT (PPM) | LAB RESULT (PPM) |
|----------|--------------------|------------------|
| 05/03/02 | 0.9 | 0.7 |
| 05/10/02 | 0.7 | 0.6 |
| 05/17/02 | 0.9 | 0.6 |
| 05/24/02 | 0.9 | 0.4 |
| 05/31/02 | 0.8 | 0.5 |
| 06/07/02 | 1.2 | 1.2 |

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician