

Results Report

State Health Dept # : 12-WB-06848

Report To	JERICO UNDERHILL WATER	WSID	VT0005096
ATTN OF	MARC MAHEUX	Account Name	JERICO UNDERHILL WATER
Address	PO BOX 174	Date Received	10/01/2012
		Time Received	09:35
	UNDERHILL, VT 05489	Approved Date	10/02/2012

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	10/01/2012	Free Chlorine Residual	0.05 mg/L
Collection Time	08:45	Total Chlorine Residual	
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Kitchen Sink/RW100	Field Temp.	
Street Address	100 Raceway	Field Fluoride	
Town	Jericho	Temp at Receipt	

Test Enzyme Substrate Test


Date/Time of Analysis 10/02/2012 10:50
Test Method: SM20 9223B

Analyte	Result
Total Coliform	Not detected
E.coli	Not detected

Units of Measurement and Definitions: mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit,
TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:



Mary Celotti, Laboratory Director

*If you have received this report in error or have questions about this report,
please call the laboratory at (802) 863-7336.*