VERMONT

Department of Health
Division of Health Improvement
Office of Oral Health
108 Cherry Street - PO Box 70
Burlington, VT 05402-0070
www.HealthyVermonters.info

[phone] 802-863-7341
[fax] 802-951-1218

Agency of Human Services

September 30, 2005

Marc Maheux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear Marc ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT(PPM)	LAB RESULT(PPM)
06/24/05	1.3	0.9
07/08/05	1.2	1.0
07/15/05	1.2	1.0
07/22/05	1.2	1.0
07/29/05	1.1	1.0
08/05/05	1.1	0.9
08/12/05	1.0	0.8
08/19/05	0.9	0.8
08/26/05	1.0	0.9
09/02/05	1.1	0.9
09/09/05	1.1	1.0
09/16/05	1.2	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician