



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

April 1, 2004

Mare Makeux
~~Helen Miller~~

Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear ~~Mrs.~~ *Mare* Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
01/30/04	1.0	0.6
01/23/04	0.9	0.1
02/06/04	1.0	0.7
02/13/04	1.0	0.7
02/20/04	1.0	0.7
02/27/04	1.0	0.7
03/05/04	1.1	0.7
03/12/04	1.0	0.6

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician