



VERMONT

Department of Health

Division of Health Improvement

Office of Oral Health

108 Cherry Street - PO Box 70

Burlington, VT 05402-0070

www.HealthyVermonters.info

Agency of Human Services

[phone] 802-863-7341

[fax] 802-951-1218

December 11, 2006

Marc Mahoney
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
10/06/06	1.2	0.9
10/13/06	1.1	0.9
10/20/06	1.1	0.9
10/27/06	1.2	1.0
11/03/06	1.0	0.9
11/10/06	1.2	0.9
11/24/06	1.1	1.0
Missing date	Missing data	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund
Alida I. Lund
Fluoridation Technician