

Laboratory Report



Jericho Underhill Water 100300
P.O. Box 174
Underhill, VT 05489

PROJECT: WSID 5096 TC
WORK ORDER: 2111-34725
DATE RECEIVED: November 23, 2021
DATE REPORTED: November 24, 2021
SAMPLER: Andy **VT0005096**

001 Site: 45 Poker Hill Rd. Date Sampled: 11/22/21 Time: 19:45

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Free Chlorine Residual (Field Result):	0.01	ppm					
Total Coliform	Absent	/100 mL	SM20 9223B(04)	11/23/21 13:54	W AKJ	A	
E. coli	Absent	/100 mL	SM20 9223B(04)	11/23/21 13:54	W AKJ	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director

www.endynelabs.com



160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893



WSID 5096

Total Coliform
Endyne Inc. COC

2111-34725



Jericho Underhill Water
WSID 5096 TC

Bill to:
Andy Foresburg
Underhill Water
PO Box 174
Underhill VT 05489
Ph: 802-363-4586

Report to:
Andy Foresburg
Jericho Underhill Water
PO Box 174
Underhill VT 05489
jwater899@yahoo.com;kirk@champ

Prepared: 6/25/21
Cust # 101
VT0005096
TC0005096

Was the water system chlorinated at the time of sample collection? Circle one: YES NO

Sampler:

Circle Sample Type for each sample RT RP SP 1 Sterile 120 mL Bottle per Sample

Andy

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: 0.01 mg/L
001 45 Parker Hill Rd Sampled Date/Time: 11/22/21 @ 19:45pm Chlorine, Total: _____ mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: _____ mg/L
002 _____ Sampled Date/Time: ____/____/____ @ _____ Chlorine, Total: _____ mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: _____ mg/L
003 _____ Sampled Date/Time: ____/____/____ @ _____ Chlorine, Total: _____ mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: _____ mg/L
004 _____ Sampled Date/Time: ____/____/____ @ _____ Chlorine, Total: _____ mg/L

Fac.ID: DS001 Smp Pt: TC001 Ctg: TC Smp Typ: RT RP SP Repl: Y/N Cmpl Ind: Y/N Chlorine, Free: _____ mg/L
005 _____ Sampled Date/Time: ____/____/____ @ _____ Chlorine, Total: _____ mg/L

CHLORINATED

Relinquished by: [Signature] 11/23/21 Date Time Accepted by: [Signature] 11/23/21 @ 7:43 Date Time

Relinquished by: _____ Date Time Received by: _____ Date Time

Sites/Parameters correct as listed. Client Initials KP

Client Authorization to use Subcontract lab Client Initials KP

Sample origin: VT NH NY Other

Requested Turnaround Time: Routine: Rush Due Date _____

Delv: <u>Client</u>	Temp C: <u>12.2</u>	Comment:	Tmpl Ck	Lab use Only
			Log by	



160 James Brown Dr.
Williston, VT 05495
Ph 802-879-4333
Fax 802-879-7103

56 Etna Road
Lebanon, NH 03766
Ph 603-678-4891
Fax 603-678-4893

315 New York Rd.
Plattsburgh, NY 12903
Ph 518-563-1720
Fax 518-563-0052