



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

September 25, 2003

maie makeux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

maie
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
07/11/03	1.3	1.1
07/18/03	1.3	1.1
07/25/03	1.3	1.2
08/08/03	1.0	0.6
08/15/03	1.2	1.0
08/22/03	1.2	1.1
08/29/03	1.1	1.0
Missing date	Missing data	1.1

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician