



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

December 28, 2004

Helen Miller
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear Mrs. Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
10/22/04	1.1	0.9
10/29/04	1.0	0.9
11/05/04	1.0	0.9
11/12/04	1.1	0.9
11/19/04	1.2	1.0
11/26/04	1.1	1.0
12/03/04	1.2	1.0
12/03/04	1.2	0.9
12/10/04	1.1	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund
Fluoridation Technician