

VERMONT DEPARTMENT OF HEALTH LABORATORY
 359 SOUTH PARK DRIVE
 COLCHESTER, VT 05446
 (802) 338-4724 (800) 660-9997 (VT ONLY)

ANALYSIS of WATER for HALOACETIC ACIDS using Method 552.2 (GC/ECD)

LITS Number 2018003327-001-A

State Health Dept No. 19S00024

Kit Type Kit OK (haloacetic acids)

WSID# 0000005096

Kit Number

Address Marc Maheux
 Jericho Underhill Water

JERICH0-UNDERHILL WATER

Sampler Title

PO Box 174
 Underhill VT 05489

Purpose of Sample Compliance Monitor

Type of Sample

CHLORINE, FREE 0.06

Date/Time Received 08/13/2018 11:51:00

CHLORINE, TOTAL

Date/Time of Sampling 08/13/2018 08:40:00

Field Temp (C)

Report Status Final

Sample Location 7 Park St/ 3 Bay

Date Reported 08/22/2018

Town Underhill

Sample Number

Released By JPM

Collected By Marc Maheux

Haloacetic Acids	Result	Units	Limit
Chloroacetic Acid	< 0.001	mg/L	
Bromoacetic Acid	< 0.001	mg/L	
Dichloroacetic Acid	< 0.001	mg/L	
Trichloroacetic Acid	< 0.001	mg/L	
Dibromoacetic Acid	< 0.001	mg/L	
Total Haloacetic Acids	< 0.005	mg/L	Total HAA's 0.06 mg/L MCL

Comments:

Note: Sample temperature at time of receipt was greater than approved method preservation requirements: evidence of cooling was observed.

Registry Comments:

Definitions: < = Less than > = Greater than MCL=Maximum Contaminant Level VHA=Vermont Health Advisory
 mg/L = milligrams per liter or PPM (parts per million) ug/L = micrograms per liter or PPB (parts per billion)

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320. Results relate only to the items tested.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Page: 1 / 1

Date Printed: 08/22/2018 14:14:22

If you have questions about this report, please call the laboratory at (802)338-4724.