



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # 20-IC-08291
Report Status Final
Date Report Released 03/30/2020

Report To Jericho Underhill Water
ATTN of Andy Forsberg
Address PO Box 174
Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 03/20/2020
Time Received 11:31
Approved Date 03/30/2020

Sample Desc. Munic FI
Collection Date 03/18/2020
Collection Time 07:45
Sampled By Helen Miller
Sampling Location Kitchen Sink
Street Address 406 Vt Rt 15
Town Underhill State VT
Sample Type Routine/Comp
Collection Type N/A
Free Chlorine Residual N/A
Total Chlorine Residual N/A
Chlorinated? N/A
Field Temp. N/A
Field Fluoride 1.0 mg/L
Temp at Receipt N/A

Test Anions
Date/Time of Analysis 03/20/2020 15:31
Test Method EPA 300.0

Analyte Final Result Units Limit
Fluoride 0.43 mg/L 4.0 MCL

Units of Measurement and Definitions:

N/A = Not Available; mg/L = Milligrams per liter or ppm (parts per million); ug/L = Micrograms per liter or ppb (parts per billion); < = less than; TON = Threshold Odor Number; MCL = Maximum Contaminant Level; SMCL = Secondary Maximum Contaminant Level; MRDL = Maximum Residual Disinfectant Level; VHA = Vermont Health Advisory; VMCL = Vermont Maximum Contaminant Level; NLE = No Limit Established; AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

Unless otherwise noted all analyses performed under NELAP certification have complied with all the requirements for the TNI standard.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit www.healthvermont.gov/water-contaminants.

This report shall not be reproduced, except in full, without approval of the laboratory.

Test Report Authorized By: Dominic Reynolds
Laboratory Program Chief - Chemistry

If you have received this document in error or if you have questions about this report, please call 802-338-4724