

VERMONT DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE

BURLINGTON, VERMONT 05402-1125

(802) 863-7335 (800) 660-9997 (VT ONLY)

ANALYSIS of WATER for EDB and DBCP using Method 504

LITS Number 2013004927-001-A

State Health Dept No. 14S00008

Kit Type Kit OH (EDB/DBCP)

WSID# 0000005096

Kit Number

Report To: MARC MAHEUX
Address JERICO-UNDERHILL WATER

PO BOX 174
UNDERHILL VT 05489

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title

Purpose of Sample Compliance Monitor

Type of Sample

CHLORINE, FREE 0.07

CHLORINE, TOTAL

Not chlorinated

Field Temp (C)

Date/Time Received 07/08/2013 12:04:00

Date/Time of Sampling 07/08/2013 08:45:00

Report Status Final

Sample Location entry point/52 river rd

Date Reported 07/16/2013

Collected By MARC MAHEUX

Released By JPM

Sample Number

Analyte	Result	Units	Limit
Ethylene Dibromide (EDB)	< 0.02	ug/L	0.05 ug/L MCL
Dibromochloropropane (DBCP)	< 0.02	ug/L	0.20 ug/L MCL

Comments:

Sample was received above method specified temperature, but there was evidence of cooling.
JPM 7/16/13

Registry Comments:

Definitions: <= Less than >= Greater than MCL = Maximum Contaminant Level VHA = Vermont Health Advisory
mg/L = milligrams per liter or PPM (parts per million) ug/L = micrograms per liter or PPB (parts per billion)

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A. 315-320). Results relate only to the items tested.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Page: 1 / 1

Date Printed: 07/16/2013 14:06:19

If you have questions about this report, please call the Laboratory at (802)863-7335.