

**VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)
WATER BACTERIOLOGY RESULTS**

LITS Number 2011015778-001-A

State Health Dept No. 12WB02327

Kit Type Kit AA Coliform (Regulated Systems)

WSID#

0000005096

Kit Number

MARC MAHEUX
JERICHO-UNDERHILL WATER

Report To

PO BX 174
UNDERHILL VT 05489

Public Water System Only

JERICHO-UNDERHILL WATER

Sampler Title

Purpose of Sample Routine

Type of Sample

Chlorine, free 0.1

Chlorine, total

Not chlorinated —

Field Temp (C)

Action Limit

Date/Time Received 09/06/2011 10:07:00

Date/Time of Collection 09/06/2011 07:40:00

Town

Collected By MARC MAHEUX

Date Analyzed 09/07/2011

Sample Location

Report Status Final

Field Sample Number

Date Reported 09/07/2011

Released by KBW

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320)

Results relate only to the items tested. This water was not analyzed for chlorine residual.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 09/07/2011 11:58:55