

VERMONT DEPARTMENT OF HEALTH LABORATORY
 195 COLCHESTER AVENUE
 BURLINGTON, VERMONT 05402-1125
 (802) 863-7335 (800) 660-9997 (VT ONLY)

ANALYSIS of WATER for HALOACETIC ACIDS using Method 552.2 (GC/ECD)

LITS Number 2015003787-001-A

State Health Dept No. 16S00019

Kit Type Kit OK (haloacetic acids)

WSID# 0000005096

Kit Number

Address MARC MAHEUX
 JERICHO-UNDERHILL WATER
 38 POKER HILL RD
 PO BOX 174
 UNDERHILL VT 05489

JERICHO-UNDERHILL WATER

Sampler Title
 Purpose of Sample Compliance Monitor
 Type of Sample
 CHLORINE, FREE 0.11
 CHLORINE, TOTAL
 Field Temp (C)

Date/Time Received 08/05/2015 16:26:00

Date/Time of Sampling 08/04/2015 15:45:00

Report Status Final

Sample Location 7 Park St/3 Bay sink

Date Reported 08/17/2015

Collected By Marc Maheux

Released By JPM

Sample Number

Haloacetic Acids	Result	Units	Limit
Chloroacetic Acid	< 0.001	mg/L	
Bromoacetic Acid	< 0.001	mg/L	
Dichloroacetic Acid	< 0.001	mg/L	
Trichloroacetic Acid	< 0.001	mg/L	
Dibromoacetic Acid	< 0.001	mg/L	
Total Haloacetic Acids	< 0.005	mg/L	Total HAA's 0.06 mg/L MCL

Comments:

*Result Qualified: The temperature of the sample when received at the laboratory was greater than approved method preservation requirements however there was evidence of cooling. The test method used requires cooling from the time of sample collection.

Registry Comments:

Definitions: < = Less than > = Greater than MCL=Maximum Contaminant Level VHA=Vermont Health Advisory
 mg/L = milligrams per liter or PPM (parts per million) ug/L = micrograms per liter or PPB (parts per billion)

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320. Results relate only to the items tested.

This report shall not be reproduced, except in full, without the written approval of the laboratory.