

VERMONT DEPARTMENT OF HEALTH LABORATORY  
195 COLCHESTER AVENUE  
BURLINGTON, VERMONT 05402-1125  
(802) 863-7335 (800) 660-9997 (VT ONLY)

INORGANIC CHEMISTRY REPORT

LITS Number 2011000114-001-A

State Health Dept No. 11C1931

Kit Type Nitrate

WSID# 0000005096

Kit Number 9679212

Report To MARC MAHEUX  
Address JERICO-UNDERHILL WATER  
38 POKER HILL RD  
PO BX 236  
UNDERHILL VT 05489

Public Water System Only

JERICO-UNDERHILL WATER  
Sampler Title OPERATOR  
Purpose of Sample Compliance Monitor  
Type of Sample Entry Point  
CHLORINE, TOTAL (mg/L)  
CHLORINE, FREE (mg/L)  
Field Temp (C)

Date/Time Received 02/11/2011 08:46:00

Date/Time of Collection 02/11/2011 07:32:00

Town Underhill

Person Taking Sample SARA M RITTER

Sample Location control building/entry point tap

Date Analyzed

Field Sample Number

Report Status Final

Date Reported 02/23/2011

Released by CLB

Anions	Result	Units	Method	Limits
Total Nitrate & Nitrite*	< 0.5	mg/L	Lachat 10-107-04-1-A	10. mg/L MCL (as Nitrogen)

Comments:

Registry Comments:

Definitions: mg/L = milligrams per liter, or ppm (parts per million) < = less than  
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level VHA = Vermont Health Advisory  
Action Level = level at or above which a water treatment action is determined for public water supplies  
and should be considered for private supplies. \* Total Nitrate and Nitrite = Nitrate-Nitrite, total measured as Nitrogen.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A 315 - 320). Results relate only to the items tested. This report shall not be reproduced, except in full, without the written approval of the laboratory.

Page: 1 / 1

Date Printed: 02/23/2011 09:45:59

If you have questions about this report, please call the Laboratory at (802)863-7335.