



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 12-IB-00396

Report To: JERICO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICO UNDERHILL WATER
Date Received: 06/28/2012
Time Received: 11:38
Approved Date: 07/10/2012

Sample Desc.: KIT IB - Lead/Copper
Collection Date: 06/28/2012
Collection Time: 05:17
Sampled By: Wendy Garrapy
Sampling Location: Garrapy Wendy & Bruce,19/PH032
Street Address: 32 Poker Hill Rd
Town: Underhill

Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test Metals by ICPMS

Date/Time of Analysis: 07/09/2012 11:51
Test Method: EPA 200.8 IB

Table with 4 columns: Analyte, Final Result, Units, Limit. Rows for Copper and Lead.

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.

**Results Report**

**State Health Dept # : 12-IB-00397**

<b>Report To</b>	JERICO UNDERHILL WATER	<b>WSID</b>	VT0005096
<b>ATTN OF</b>	MARC MAHEUX	<b>Account Name</b>	JERICO UNDERHILL WATER
<b>Address</b>	PO BOX 174	<b>Date Received</b>	06/28/2012
	UNDERHILL, VT 05489	<b>Time Received</b>	11:39
		<b>Approved Date</b>	07/10/2012

<b>Sample Desc.</b>	KIT IB - Lead/Copper	<b>Sample Type</b>	Routine/Comp
<b>Collection Date</b>	06/28/2012	<b>Free Chlorine Residual</b>	
<b>Collection Time</b>	06:02	<b>Total Chlorine Residual</b>	
<b>Sampled By</b>	David K. Damkot	<b>Chlorinated?</b>	
<b>Sampling Location</b>	Bathroom Sink, 1/VT379	<b>Field Temp.</b>	
<b>Street Address</b>	379 VT Route 15	<b>Field Fluoride</b>	
<b>Town</b>	Jericho	<b>Temp at Receipt</b>	

<b>Test</b>	<b>Metals by ICPMS</b>	<b>Date/Time of Analysis</b>	07/09/2012 11:49
		<b>Test Method:</b>	EPA 200.8 IB


Analyte	Final Result	Units	Limit
Copper	0.21	mg/L	1.3 AL
Lead	<0.001	mg/L	0.015 AL

**Units of Measurement and Definitions:**

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) <= less than TON = Threshold Odor Number  
 MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level  
 VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established  
 AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.  
 Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.  
 This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont  
 Access to Public Documents law (1 V.S.A. 315-320).  
 This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:



Mary Celotti, Laboratory Director

**If you have received this report in error or if you have questions about this report,  
 please call the laboratory at (802) 863-7336.**

**Results Report**

**State Health Dept # : 12-IB-00398**

<b>Report To</b>	JERICO UNDERHILL WATER	<b>WSID</b>	VT0005096
<b>ATTN OF</b>	MARC MAHEUX	<b>Account Name</b>	JERICO UNDERHILL WATER
<b>Address</b>	PO BOX 174	<b>Date Received</b>	06/28/2012
	UNDERHILL, VT 05489	<b>Time Received</b>	11:38
		<b>Approved Date</b>	07/10/2012

<b>Sample Desc.</b>	KIT IB - Lead/Copper	<b>Sample Type</b>	Routine/Comp
<b>Collection Date</b>	06/24/2012	<b>Free Chlorine Residual</b>	
<b>Collection Time</b>	07:20	<b>Total Chlorine Residual</b>	
<b>Sampled By</b>	Marie Anestopoulos	<b>Chlorinated?</b>	
<b>Sampling Location</b>	Anestopoulos Marie P, 3/LL005	<b>Field Temp.</b>	
<b>Street Address</b>	5 Liberty Ln	<b>Field Fluoride</b>	
<b>Town</b>	Jericho	<b>Temp at Receipt</b>	

<b>Test</b>	<b>Metals by ICPMS</b>	<b>Date/Time of Analysis</b>	07/09/2012 11:45
		<b>Test Method:</b>	EPA 200.8 IB
<b>Analyte</b>	<b>Final Result</b>	<b>Units</b>	<b>Limit</b>
Copper	0.13	mg/L	1.3 AL
Lead	<0.001	mg/L	0.015 AL

**Units of Measurement and Definitions:**

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number  
 MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level  
 VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established  
 AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.  
 Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.  
 This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont  
 Access to Public Documents law (1 V.S.A. 315-320).  
 This report shall not be reproduced, except in full, without the written approval of the laboratory.

**Test Report Authorized By:** *Mary Celotti*  
 Mary Celotti, Laboratory Director

**If you have received this report in error or if you have questions about this report,  
 please call the laboratory at (802) 863-7336.**



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 12-IB-00399

Report To: JERICHO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICHO UNDERHILL WATER
Date Received: 06/29/2012
Time Received: 08:20
Approved Date: 07/10/2012

Sample Desc.: KIT IB - Lead/Copper
Collection Date: 06/29/2012
Collection Time: 04:43
Sampled By: Krystal Williams
Sampling Location: Jolley Associates, 5/VT341
Street Address: 341 VT Route 15
Town: Jericho

Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test Metals by ICPMS

Date/Time of Analysis: 07/09/2012 13:01
Test Method: EPA 200.8 IB

Table with 4 columns: Analyte, Final Result, Units, Limit. Rows for Copper and Lead.

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.

**Results Report**

**State Health Dept # : 12-IB-00400**

**Report To** JERICO UNDERHILL WATER  
**ATTN OF** MARC MAHEUX  
**Address** PO BOX 174  
 UNDERHILL, VT 05489

**WSID** VT0005096  
**Account Name** JERICO UNDERHILL WATER  
**Date Received** 06/28/2012  
**Time Received** 11:39  
**Approved Date** 07/11/2012

**Sample Desc.** KIT IB - Lead/Copper  
**Collection Date** 06/28/2012  
**Collection Time** 06:40  
**Sampled By** Roger Miller  
**Sampling Location** Ktc Sink, 7/VT449  
**Street Address** 449 VT RT 15  
**Town** Underhill

**Sample Type** Routine/Comp  
**Free Chlorine Residual**  
**Total Chlorine Residual**  
**Chlorinated?**  
**Field Temp.**  
**Field Fluoride**  
**Temp at Receipt**

**Test Metals by ICPMS**

**Date/Time of Analysis** 07/10/2012 13:42

**Test Method:** EPA 200.8 IB

Analyte	Final Result	Units	Limit
Copper	0.81	mg/L	1.3 AL
Lead	0.002	mg/L	0.015 AL

**Units of Measurement and Definitions:**

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number  
 MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level  
 VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established  
 AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

**Test Report Authorized By:**

*Mary Celotti*  
 Mary Celotti, Laboratory Director

**If you have received this report in error or if you have questions about this report,  
 please call the laboratory at (802) 863-7336.**

**Results Report**

**State Health Dept # : 12-IB-00401**

<b>Report To</b>	JERICO UNDERHILL WATER	<b>WSID</b>	VT0005096
<b>ATTN OF</b>	MARC MAHEUX	<b>Account Name</b>	JERICO UNDERHILL WATER
<b>Address</b>	PO BOX 174	<b>Date Received</b>	06/28/2012
	UNDERHILL, VT 05489	<b>Time Received</b>	11:39
		<b>Approved Date</b>	07/10/2012

<b>Sample Desc.</b>	KIT IB - Lead/Copper	<b>Sample Type</b>	
<b>Collection Date</b>	06/28/2012	<b>Free Chlorine Residual</b>	
<b>Collection Time</b>	07:30	<b>Total Chlorine Residual</b>	
<b>Sampled By</b>	Rebecca Baker	<b>Chlorinated?</b>	
<b>Sampling Location</b>	Tyler & Rebecca Baker, 17 & RW101	<b>Field Temp.</b>	
<b>Street Address</b>	101 Raceway Rd	<b>Field Fluoride</b>	
<b>Town</b>	Jericho	<b>Temp at Receipt</b>	

<b>Test</b>	<b>Metals by ICPMS</b>	<b>Date/Time of Analysis</b>	07/09/2012 11:44
		<b>Test Method:</b>	EPA 200.8 IB

Analyte	Final Result	Units	Limit
Copper	0.09	mg/L	1.3 AL
Lead	<0.001	mg/L	0.015 AL

**Units of Measurement and Definitions:**

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number  
 MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level  
 VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established  
 AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.  
 Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.  
 This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont  
 Access to Public Documents law (1 V.S.A. 315-320).  
 This report shall not be reproduced, except in full, without the written approval of the laboratory.

**Test Report Authorized By:** *Mary Celotti*  
 Mary Celotti, Laboratory Director

***If you have received this report in error or if you have questions about this report,  
 please call the laboratory at (802) 863-7336.***



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 12-IB-00402

Report To: JERICHO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICHO UNDERHILL WATER
Date Received: 06/28/2012
Time Received: 11:39
Approved Date: 07/10/2012

Sample Desc.: KIT IB - Lead/Copper
Collection Date: 06/28/2012
Collection Time: 07:40
Sampled By: Alan Morse
Sampling Location: Ktc Sink, 16/MD018
Street Address: 18 Meadow Ln
Town: Underhill

Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test Metals by ICPMS

Date/Time of Analysis: 07/09/2012 11:43
Test Method: EPA 200.8 IB

Table with 4 columns: Analyte, Final Result, Units, Limit. Rows include Copper (0.04 mg/L, 1.3 AL) and Lead (<0.001 mg/L, 0.015 AL).

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 12-IB-00403

Report To: JERICHO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICHO UNDERHILL WATER
Date Received: 06/28/2012
Time Received: 11:39
Approved Date: 07/10/2012

Sample Desc.: KIT IB - Lead/Copper
Collection Date: 06/28/2012
Collection Time: 08:00
Sampled By: Morin
Sampling Location: Underhill Garage Inc, 12/VT401
Street Address: 401 Route 15
Town: Underhill

Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test Metals by ICPMS

Date/Time of Analysis: 07/09/2012 11:41
Test Method: EPA 200.8 IB

Table with 4 columns: Analyte, Final Result, Units, Limit. Rows for Copper and Lead.

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 12-IB-00404

Report To: JERICHO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICHO UNDERHILL WATER
Date Received: 06/28/2012
Time Received: 11:38
Approved Date: 07/10/2012

Sample Desc.: KIT-IB - Lead/Copper
Collection Date: 06/28/2012
Collection Time: 06:15
Sampled By: Deirdre Goldenbogen
Sampling Location: United Church of, 9/PA009X
Street Address: 9 Park St
Town: Underhill

Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test Metals by ICPMS

Date/Time of Analysis: 07/09/2012 11:37
Test Method: EPA 200.8 IB

Table with 4 columns: Analyte, Final Result, Units, Limit. Rows for Copper and Lead.

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 12-IB-00405

Report To: JERICHO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICHO UNDERHILL WATER
Date Received: 06/28/2012
Time Received: 11:39
Approved Date: 07/10/2012

Sample Desc.: KIT IB - Lead/Copper
Collection Date: 06/28/2012
Collection Time: 05:45
Sampled By: Lawrence E. LeCours
Sampling Location: Lecours Lawrence & S, 13/RW123
Street Address: 123 Raceway Rd
Town: Jericho

Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test: Metals by ICPMS
Date/Time of Analysis: 07/09/2012 13:00
Test Method: EPA 200.8 IB

Table with 4 columns: Analyte, Final Result, Units, Limit. Rows for Copper and Lead.

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report, please call the laboratory at (802) 863-7336.