VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)
WATER BACTERIOLOGY RESULTS

LITS Number 2010025042-001-A **State Health Dept No.** 11WB03673

Kit Type Kit AA Coliform (Regulated Systems) **WSID#** 0000005096

Kit Number 9674123

Report To
MARC MAHEUX
JERICHO-UNDERHILL WATER
38 POKER HILL RD
PO BX 236
UNDERHILL VT 05489

Public Water System Only

JERICHO-UNDERHILL WATER	
Sampler Title	OPERATOR
Purpose of Sample	Routine
Type of Sample	Distribution
Chlorine, free	0.10
Chlorine, total	
Not chlorinated	—
Field Temp (C)	
Action Limit	

Date/Time Received 11/02/2010 10:26:00

Date/Time of Collection 11/02/2010 07:15:00

Town Underhill

Collected By MARC MAHEUX

Date Analyzed 11/03/2010

Sample Location 38 POKER HILL RD - KITCHEN SINK

Report Status Final

Field Sample Number

Date Reported 11/03/2010

Released by LLK

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, persuant to Vermont Access to Public Documents law (1V.S.A.315-320)

Results relate only to the items tested. This water was not analyzed for chlorine residual.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 11/03/2010 12:27:28