



DEPARTMENT OF HEALTH LABORATORY

195 COLCHESTER AVENUE
PO BOX 1125
BURLINGTON, VT 05402-1125
(802) 863-7336 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept #: 11-IC-01779

Report To: JERICO UNDERHILL WATER
ATTN OF: MARC MAHEUX
Address: PO BOX 174
UNDERHILL, VT 05489

WSID: VT0005096
Account Name: JERICO UNDERHILL WATER
Date Received: 05/14/2012
Time Received: 08:18
Approved Date: 05/17/2012

Sample Desc.: Munic FI
Collection Date: 05/11/2012
Collection Time: 09:00
Sampled By: Helen Miller
Sampling Location: Kitchen Sink
Street Address: 406 VT Rte 15
Town: Underhill
Sample Type: Routine/Comp
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride: 0.9 mg/L
Temp at Receipt

Test: Fluoride
Date/Time of Analysis: 05/16/2012 11:07
Test Method: LACHAT 10-109-12-2-A

Table with 4 columns: Analyte, Final Result, Units, Limit. Row 1: Fluoride, 0.4, mg/L, 4.0 MCL

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
Access to Public Documents law (1 V.S.A. 315-320).
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: Mary Celotti
Mary Celotti, Laboratory Director

If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.