



**Vermont Department of Health**  
Division of Health Improvement  
Dental Health Services

*Agency of Human Services*

January 4, 2001

*Marc Mayheux*  
~~Helen Miller~~  
Jericho/Underhill Water District  
406 VT. Rte. 15  
Underhill VT 05489

*Marc*  
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
10/27/00	1.2	1.1
11/03/00	1.2	1.2
11/10/00	1.3	1.2
11/17/00	1.2	1.1
11/24/00	MISSING DATA	MISSING DATA
12/08/00	1.2	1.0
12/15/00	1.2	1.1

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

*Alida Lund*

Alida I. Lund  
Fluoridation Technician