



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

August 26, 2004

Marc Mahoney

~~Helen Miller~~

Jericho/Underhill Water District

406 VT. Rte. 15

Underhill VT 05489

Marc
Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
06/18/04	1.1	1.0
06/25/04	1.0	1.0
07/02/04	1.2	1.0
07/09/04	1.1	1.0
07/16/04	1.2	1.0
07/23/04	1.1	1.1
07/30/04	1.1	1.0
08/06/04	1.1	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund

Fluoridation Technician