

Results Report

State Health Dept # : 11-IC-01773

| | | | |
|------------------|------------------------|----------------------|------------------------|
| Report To | JERICO UNDERHILL WATER | WSID | VT0005096 |
| ATTN OF | MARC MAHEUX | Account Name | JERICO UNDERHILL WATER |
| Address | PO BOX 174 | Date Received | 09/19/2011 |
| | UNDERHILL, VT 05489 | Time Received | 08:47 |
| | | Approved Date | 09/26/2011 |

| | | | |
|--------------------------|---------------------|--------------------------------|--------------|
| Sample Desc. | Munic FI | Sample Type | Routine/Comp |
| Collection Date | 09/16/2011 | Free Chlorine Residual | |
| Collection Time | 07:46 | Total Chlorine Residual | |
| Sampled By | H MILLER | Chlorinated? | |
| Sampling Location | | Field Temp. | |
| Street Address | 406 VT RTE 15 | Field Fluoride | 0.9 mg/L |
| Town | Underhill (Town of) | Temp at Receipt | |

| | | | |
|-------------|-----------------|------------------------------|----------------------|
| Test | Fluoride | Date/Time of Analysis | 09/20/2011 11:36 |
| | | Test Method: | LACHAT 10-109-12-2-A |

| Analyte | Final Result | Limit | Units |
|----------|--------------|---------|-------|
| Fluoride | 0.8 | 4.0 MCL | mg/L |

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.
 Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.
 This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont
 Access to Public Documents law (1 V.S.A. 315-329).
 This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti
 Mary Celotti, Laboratory Director

Edmond P. Luce
 Edmond P. Luce, Quality Systems Specialist

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
 MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
 VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
 AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

If you have questions about this report, please call the laboratory at (802) 863-7336.