VERMONT DEPARTMENT OF HEALTH LABORATORY
359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 (800) 660-9997 (VT ONLY)

ANALYSIS of WATER for TRIHALOMETHANES using Method 524.2

LITS Number 2018003328-001-A **State Health Dept No.** 19V00028

Kit Type Kit OB (trihalomethanes) **WSID#** 0000005096
Kit Number

Marc Maheux
Address Jericho Underhill Water

PO Box 174
Underhill VT 05489

JERICHO-UNDERHILL WATER
Sampler Title
Purpose of Sample Compliance Monitor
Type of Sample
CHLORINE, FREE 0.01
CHLORINE, TOTAL
Field Temp (C)

Date/Time Received 08/13/2018 11:51:00
Date/Time of Sampling 08/13/2018 07:45:00

Report Status Final **Sample Location** 38 Poker Hill/ Kitchen Sink
Date Reported 08/14/2018 **Town** Underhill **Sample Number**
Released By JPM **Collected By** Marc Maheux

Trihalomethanes	Result	Units	Limit
Chloroform	0.002	mg/L	
Bromodichloromethane	0.001	mg/L	
Dibromochloromethane	0.001	mg/L	
Bromoform	< 0.0005	mg/L	
Total Trihalomethanes	0.004	mg/L	0.080 mg/L MCL

Comments:
Note: Sample temperature at time of receipt was greater than approved method preservation requirements: evidence of cooling was observed.

Registry Comments:

Definitions: < = Less than > = Greater than MCL = Maximum Contaminant Level VHA = Vermont Health Advisory mg/L = milligrams per liter or PPM (parts per million) ug/L = micrograms per liter or PPB (parts per billion)

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, persuant to Vermont Access to Public Documents law (1 V.S.A. 315-320). Results relate only to the items tested.
This report shall not be reproduced, except in full, without the written approval of the laboratory.

Date Printed: 08/14/2018 09:31:38
If you have questions about this report, please call the laboratory at (802)338-4724.