



DEPARTMENT OF HEALTH

Department of Health

Division of Health Promotion and Disease Prevention

Office of Oral Health

108 Cherry Street, PO Box 70

Burlington, Vt 05402-0070

www.healthvermont.gov

(phone) 802-863-7341

(fax) 802-651-1634

Helen Miller

Jericho Underhill Water District

401 VT. Rte. 15

Underhill, Vt. 05489

Dear Helen,

Below are your results from the recent lab samples submitted to the Department of Health Laboratory compared to your field.

Date	Field results	Lab results	Difference
10/01/2010	1.00 ppm	0.80 ppm	0.20 ppm
10/08/2010	0.80 ppm	0.70 ppm	0.10 ppm
10/15/2010	0.90 ppm	0.70 ppm	0.20 ppm
10/22/2010	1.00 ppm	0.78 ppm	0.22 ppm
10/29/2010	1.00 ppm	0.77 ppm	0.23 ppm

Split Average: field: 0.94 ppm lab: 0.75 ppm

October monthly average: 0.92 ppm

High: 1.10 ppm

Low: 0.80 ppm

Thank you for your continued interest in water fluoridation for your community.

Sincerely yours,

Linda Greaves, RDH

Fluoridation Program

Office of Oral Health

PO Box 70, Drawer 38

Burlington, Vt 05402

802-651-1635