



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

April 1, 2005

Marc Mahely

~~Heleen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc

Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
01/28/05	1.0	0.9
02/11/05	1.0	0.8
02/18/05	1.0	0.8
02/25/05	1.0	0.7
03/04/05	0.9	0.7
03/11/05	1.0	0.6
No date	No data	0.8

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund

Alida I. Lund
Fluoridation Technician