

VERMONT DEPARTMENT OF HEALTH LABORATORY
 359 SOUTH PARK DRIVE
 COLCHESTER, VT 05446
 (802) 338-4724 (800) 660-9997 (VT ONLY)

ANALYSIS of WATER for TRIHALOMETHANES using Method 524.2

LITS Number 2016003975-001-A

State Health Dept No. 17V00019

Kit Type Kit OB (trihalomethanes)
 Kit Number

WSID# 0000005096

Address MARC MAHEUX
 JERICHO-UNDERHILL WATER
 38 POKER HILL RD
 PO BX 236
 UNDERHILL VT 05489

JERICHO-UNDERHILL WATER

Sampler Title
 Purpose of Sample Compliance Monitor
 Type of Sample
 CHLORINE, FREE 0.01
 CHLORINE, TOTAL
 Field Temp (C) 23.6

Date/Time Received 08/04/2016 15:29:00

Date/Time of Sampling 08/04/2016 12:30:00

Report Status Final

Sample Location 38 Poker Hill/ Kitchen Sink

Date Reported 08/10/2016

Town Underhill

Sample Number

Released By JFH

Collected By Marc Maheux

Trihalomethanes	Result	Units	Limit
Chloroform	0.001	mg/L	
Bromodichloromethane	0.001	mg/L	
Dibromochloromethane	0.001	mg/L	
Bromoform	<0.0005	mg/L	
Total Trihalomethanes	0.003	mg/L	0.080 mg/L MCL

Comments:

Registry Comments:

Definitions: < = Less than > = Greater than MCL = Maximum Contaminant Level VHA = Vermont Health Advisory
 mg/L = milligrams per liter or PPM (parts per million) ug/L = micrograms per liter or PPB (parts per billion)

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320). Results relate only to the items tested.

This report shall not be reproduced, except in full, without the written approval of the laboratory.