



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report

State Health Dept # : 18-WB-04231
Report Status : Final
Date Report Released : 02/21/2019

Report To Jericho Underhill Water
ATTN OF Marc Maheux
Address PO Box 174

Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 02/20/2019
Time Received 12:29
Approved Date 02/21/2019

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	02/20/2019	Free Chlorine Residual	0.04 mg/L
Collection Time	08:30	Total Chlorine Residual	
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Mop Sink	Field Temp.	
Street Address	419 Rte 15	Field Fluoride	
Town	Underhill	Temp at Receipt	
Sampler's Comments			

Test	Enzyme Substrate Test	Date/Time of Analysis	02/21/2019 11:00
		Test Method	SM20 9223B
Analyte	Result		
Total Coliform	Not detected		
E.coli	Not detected		

Units of Measurement and Definitions:

mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit, TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary Celotti, Laboratory Director

If you have received this report in error or have questions about this report, please call the laboratory at (802) 338-4724.