



ENDYNE, INC.

Laboratory Services

160 James Brown Drive
Williston, Vermont 05495
(802) 879-4333
FAX 879-7103

LABORATORY REPORT

Jericho Underhill Water
PO Box 236
Underhill, VT 05489
Attn: Marc Maheux

PROJECT: Poker Hill Tank
ORDER ID: 44791
RECEIVE DATE: May 10, 2006
REPORT DATE: May 24, 2006

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody. Different groups of analyses may be reported under separate cover.

All samples were prepared and analyzed by requirements outlined in the referenced methods and within the specified holding times.

All instrumentation was calibrated with the appropriate frequency and verified by the requirements outlined in the referenced methods.

Blank contamination was not observed at levels affecting the analytical results.

Analytical method precision and accuracy was monitored by laboratory control standards which include matrix spike, duplicate and quality control analyses. These standards were determined to be within established laboratory method acceptance limits, unless otherwise noted.

M- Laboratory Fortified Matrix analysis indicates there may be a negative interference.

Reviewed by,

Harry B. Locker, Ph.D.
Laboratory Director

Enclosures



Laboratory Services

160 James Brown Drive
Williston, Vermont 05495
(802) 879-4333
FAX 879-7103

LABORATORY REPORT

CLIENT: Jericho Underhill Water

ORDER ID: 44791

PROJECT: Poker Hill Tank

DATE RECEIVED: May 10, 2006

REPORT DATE: May 24, 2006

SAMPLER: MM

Site:	Poker Hill Tank	
Ref. Number:	273711	Date Sampled: 5/10/06
Anal. Method:	SW 8021B	Time Sampled: 7:00 AM
Analyst:	503	Analysis Date: 5/17/06
<u>Parameter</u>	<u>Results ug/L</u>	
MTBE	< 2.0	
Benzene	< 1.0	
Toluene	< 1.0	
Ethylbenzene	< 1.0	
Xylenes, Total	< 2.0M-	
1,3,5 Trimethyl Benzene	< 1.0M-	
1,2,4 Trimethyl Benzene	< 1.0M-	
Naphthalene	< 2.0M-	
UIP's	0.	
Surrogate 1	98.%	