

**Monthly Operations Report
for Groundwater Systems and Systems Purchasing Groundwater**

For the Month of August 2016 WSID# 5096 Name of Water System Jericho Underhill Water District
Town/City Underhill Operator Name Marc Maheux Phone: 802-899-3810

Please provide the following information:

1. Is a master meter which measures total water production of the system installed and functioning
YES NO (If YES, please complete items 2-6; if NO, skip to item 5)
2. Meter Reading on Last day of reporting month: 67,658,100 Gallons
3. Meter reading on Last day of previous month: 66,304,400 Gallons
4. Difference in readings: 1,353,700 Gallons
5. Have the results of all water quality compliance analyses performed during this month been submitted to the Water Supply Division? YES NO

(If NO, please submit a copy of all results with this monthly report.)
6. If you disinfect, fluoridate or otherwise treat your water on any day of the month, or if your operating permit requires that you report daily values of flow (or other), you must also complete the reverse side of this form.
7. For systems with population greater than 3,300 (Continuous monitoring for free chlorine residuals is required):
 - Did continuous monitoring equipment fail at any time this month? YES NO
 - If so, were grab samples collected every 4 hours until continuous monitoring equipment was returned to service? YES NO
 - If continuous monitoring equipment failed, give:
_____ Date & _____ Time equipment failed
_____ Date & _____ Time it was returned to service

I certify, as the **owner or authorized representative*** of this water system, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure that the information shown is correct. In making this certification, I understand that civil and or criminal penalties may be imposed for submitting false information.

Marc Maheux 9/1/16
Signature Date

Marc Maheux
Please Type or Print Name

***Owner** means the person who owns or has an ownership interest in a Public or Non-public water system. An Owner may designate an **Authorized Representative** that has the authority to act on the owner's behalf in all matters regarding the Public or Non-public water system, and is designated to be the contact person in place of the owner for all communications from the Secretary regarding the water system. A form designating an authorized representative and signed by the Owner must be on file with the Drinking Water and Groundwater Protection Division.

Groundwater Systems and Systems Purchasing Groundwater

For the Month of August 2016 WSID# 5096 Name of Water System Jericho Underhill Water District

Minimum free chlorine residual required for 4 Log viral inactivation (mg/l):

Day of Month	Water Production	Disinfection/Chlorination (Free CL, in mg/l)		Fluoride (mg/l)	PO4
		Entry Point Daily Low ¹	Distribution System (When taking coliform sample)		
1	44350	0.10		0.7	1.26
2	44350	0.10		0.7	1.26
3	44350	0.06		0.7 #042	1.38
4	44350	0.03	0.04	0.8	1.63
5	47843	0.06		0.8	1.20
6	47843	0.10		0.7	1.20
7	47843	0.24		0.7	1.40
8	47843	0.22		0.8	1.22
9	47843	0.10		0.8	1.22
10	47843	0.18		0.8 #043	1.25
11	47843	0.10		0.7	1.25
12	38757	0.12		0.7	0.89
13	38757	0.04		0.7	1.29
14	38757	0.47		0.8	1.31
15	38757	0.38		0.8	1.38
16	38757	0.33		0.9	1.31
17	38757	0.25		0.9	1.18
18	38757	0.11		0.8 #044	1.30
19	44200	0.20		0.9	1.08
20	44200	0.10		0.7	1.08
21	44200	0.19		0.9	1.16
22	44200	0.61		0.9	1.07
23	44200	0.45		0.9	1.01
24	44200	0.26		0.9	1.37
25	44200	0.19		0.8 #045	1.17
26	43450	0.23		0.9	1.18
27	43450	0.26		0.9	1.24
28	43450	0.21		0.9	1.27
29	43450	0.16		1.0	1.20
30	43450	0.12		1.0	1.85
31	43450	0.17		0.9 #046	1.79
Totals	1353700	0.20			1.27

Note: ¹ Daily low for systems with continuous monitoring. Others – during the hour of peak flow.

***Please submit this form within 10 days after the end of the month to the following address:**

Drinking Water and Groundwater Protection Division
 1 National Life Drive, Main, 2nd Floor
 Montpelier, VT 05620-3521
 Toll free 1-800-823-6500
 Out of State 1-802-241-3400
 Fax 1-802-828-1541

This form is available electronically at <http://www.vermontdrinkingwater.org>