

VERMONT DEPARTMENT OF HEALTH LABORATORY
 195 COLCHESTER AVENUE
 BURLINGTON, VERMONT 05402-1125
 (802) 863-7335 (800) 660-9997 (VT ONLY)
 WATER BACTERIOLOGY RESULTS

LITS Number 2010025044-001-A

State Health Dept No.11WB06533

Kit Type Kit AA Coliform (Regulated Systems)

WSID# 0000005096

Kit Number 9674125

Report To
 MARC MAHEUX
 JERICO-UNDERHILL WATER
 38 POKER HILL RD
 PO BX 236
 UNDERHILL VT 05489

Public Water System Only

JERICO-UNDERHILL WATER

Sampler Title OPERATOR

Purpose of Sample Routine

Type of Sample Distribution

Chlorine, free 0.20

Chlorine, total

Not chlorinated —

Field Temp (C)

Action Limit

Date/Time Received 04/01/2011 15:22:00

Date/Time of Collection 04/01/2011 14:00:00

Town Jericho

Collected By MARC MAHEUX

Date Analyzed 04/02/2011

Sample Location 8 RIVER RD/HAND SINK

Report Status Final

Field Sample Number

Date Reported 04/04/2011

Released by KBW

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320)

Results relate only to the items tested. This water was not analyzed for chlorine residual.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 04/04/2011 12:08:37