

Results Report

State Health Dept # 19-WB-05768
Report Status Final
Date Report Released 11/20/2019

Report To Jericho Underhill Water
ATTN of Michael Willard
Address PO Box 174
Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 11/18/2019
Time Received 11:46

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	11/18/2019	Collection Type	N/A
Collection Time	08:15	Free Chlorine Residual	0.13 mg/L
Sampled By	Marc Maheux	Total Chlorine Residual	N/A
Sampling Location	Kitchen Sink	Chlorinated?	Yes
Street Address	38 Poker Hill	Field Temp.	N/A
Town	Underhill	Field Fluoride	N/A
State	VT	Temp at Receipt	N/A

Test Enzyme Substrate Test

Date/Time of Analysis 11/20/2019 11:07
Test Method SM20 9223B

Analyte	Result
Total Coliform	Not detected
E.coli	Not detected

Units of Measurement and Definitions: N/A = Not Available; mL = milliliter; ">" = greater than; "<" = less than; MPN = Most Probable Number; CFU = Colony Forming Unit; TNTC = Too Numerous To Count

Unless otherwise noted all analyses performed under NELAP certification have complied with all the requirements for the TNI standard.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit

www.healthvermont.gov/water-contaminants.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: Cheryl Achilles
Laboratory Program Chief - Microbiology

If you have received this document in error or if you have questions about this report, please call 802-338-4724