



State of Vermont

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist
RELAY SERVICE FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation
WATER SUPPLY DIVISION

The Old Pantry Building
103 South Main Street
Waterbury, VT 05671-0403
TELEPHONE (802) 241-3400
FACSIMILE (802) 241-3284

June 15, 2001

Peter Mitchell
PO Box 174
Underhill, VT 05489

RE: 5096 Jericho Underhill Water

Your water sample taken on 6/14/01 from 32 PIKERHILL is coliform positive. **You must submit 4 * REPEAT SAMPLES within 24 hours of receipt of this notice, or on Monday if this notice is received on Thursday, Friday, or Saturday.** All repeat samples must be taken on the same day and include:

1. One sample from the original sample point,
2. One sample from a tap within five connections upstream of the original sample point,
3. One sample from a tap within five connections downstream of the original sample point, and
4. One sample at any other location.

Mark these samples as "**REPEAT**" on your bacteriological form.

* If you have a chlorination system, check and adjust as needed. If you have stand-by chlorination, begin chlorinating.

FAILURE TO COLLECT the required number of **REPEAT** samples will **result in a MONITORING VIOLATION for your system.**

YOU MUST TAKE 5 SAMPLES IN THE MONTH OF July (MARKED ROUTINE).

Please call Susan Stewart, Compliance Specialist or Ruth Taylor at 1-800-823-6500 or (802) 241-3400 should you have any questions.