



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

November 2, 2001

marc mayhew

~~Helen Miller~~

Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

marc

Dear ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
09/21/01	1.2	1.0
09/28/01	1.2	1.1
10/05/01	1.3	1.1
10/12/01	1.3	1.0
10/19/01	1.2	1.0
10/26/01	1.1	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician