

**LABORATORY REPORT**

EPA 524.2

 CLIENT: Countryside Heating & Ref.  
 PROJECT: Jericho Underhill Water (WSID5096)  
 SITE: New Tank Water  
 DATE RECEIVED: September 30, 2004  
 REPORT DATE: October 12, 2004  
 ANALYSIS DATE: October 6, 2004

 ORDER ID: 32747  
 REFERENCE NUMBER: 239648  
 DATE SAMPLED: September 30, 2004  
 TIME SAMPLED: 8:30 AM  
 SAMPLER: MM  
 ANALYST: 725

<u>Parameter</u>	<u>Result</u>	<u>Parameter</u>	<u>Result</u>
Benzene	< 0.5	Hexachlorobutadiene	< 0.5
Bromobenzene	< 0.5	Isopropylbenzene	0.8
Bromochloromethane	< 0.5	4-Isopropyltoluene	< 0.5
Bromomethane	< 0.5	MTBE	< 1.0
n-Butylbenzene	< 0.5	Naphthalene	< 1.0
sec-Butylbenzene	< 0.5	n-Propylbenzene	4.9
tert-Butylbenzene	< 0.5	Styrene	< 0.5
Carbon tetrachloride	< 0.5	1,1,1,2-Tetrachloroethane	< 0.5
Chlorobenzene	< 0.5	1,1,2,2-Tetrachloroethane	< 1.0
Chloroethane	< 0.5	Tetrachloroethene	< 0.5
Chloromethane	< 0.5	Toluene	< 0.5
4-Chlorotoluene	< 0.5	1,2,3-Trichlorobenzene	< 0.5
2-Chlorotoluene	< 0.5	1,2,4-Trichlorobenzene	< 0.5
Dibromomethane	< 1.0	1,1,1-Trichloroethane	< 0.5
1,2-Dichlorobenzene	< 0.5	1,1,2-Trichloroethane	< 0.5
1,3-Dichlorobenzene	< 0.5	Trichloroethene	< 0.5
1,4-Dichlorobenzene	< 0.5	Trichlorofluoromethane	< 1.0
Dichlorodifluoromethane	< 0.5	1,2,3-Trichloropropane	< 0.5
1,1-Dichloroethane	< 0.5	1,2,4-Trimethylbenzene	< 0.5
1,2-Dichloroethane	< 0.5	1,3,5-Trimethylbenzene	< 0.5
1,1-Dichloroethene	< 0.5	Vinyl Chloride	< 0.5
cis-1,2-Dichloroethene	< 0.5	Xylenes, Total	< 1.0
trans-1,2-Dichloroethene	< 0.5	Bromodichloromethane	2.4
Dichloromethane	< 1.0	Bromoform	< 0.5
1,2-Dichloropropane	< 0.5	Chloroform	3.4
1,3-Dichloropropane	< 0.5	Dibromochloromethane	1.1
2,2-Dichloropropane	< 0.5	<b>Total Trihalomethanes</b>	<b>6.9</b>
1,1-Dichloropropene	< 0.5	Surrogate 1	104.0%
cis-1,3-Dichloropropene	< 0.5	Surrogate 2	103.0%
trans-1,3-Dichloropropene	< 0.5	UIP's	> 10.
Ethylbenzene	0.7		