

Monthly Operations Report for Groundwater Systems and Systems Purchasing Water

Version 1.30, Record generated: 10/11/2025 6:35:14 AM

Submission #: HQG-8BJ4-F5CAT, version 1

Details

Submitted: 10/10/2025 8:26:47 PM by Lane Simon

ID: VT0005096 2025 September

Submission ID: HQG-8BJ4-F5CAT

Form Input

Water System Information

Water System ID

VT0005096

Name of Water System

JERICO UNDERHILL WATER

Report Year

2025

Month Being Reported (the month the report represents, not the current month)

September

Any notes to share

Is a master meter which measures total water production of the system installed and functioning?

Yes

Meter Readings and Usage

Select how your usage is reported

Gallons

Meter reading on last day of previous month

0

Meter reading on last day of reporting month

0

Total Water Production for the Reporting Period

1294870

Displayed below is your usage (in gallons) for the most recent period for which you submitted a report. This is provided for informational purposes only.

Prior Report Total Water Production

1370124

Continuous Monitoring of Free Chlorine Residuals

For systems with a population greater than 3300, continuous monitoring for free chlorine residuals is required. Those systems should also respond to the following questions:

Did continuous monitoring fail at any time this month?

No

Are you submitting a daily detail table?

Yes

Daily Data Detail Table (1 of 1)

Facility

TP001 - TREATMENT PLANT 1

Did the facility utilize standby chlorination at any point during this reporting period

Yes

Are you writing down the numbers from the meter display or are you calculating the amount of water produced each day?

Recording the meter each day

Does the meter report in gallons or cubic feet?

Gallons

Daily Reporting Data

Day	Meter or Gallons	EP Cl Residual Daily Low (mg/L)	Fluoride (mg/L)	pH average	Phosphate Daily Low (mg/L)
09/01/2025	40613	2.082	0.91		82
09/02/2025	47168	0.475			
09/03/2025	60768	0.597	92		1.92
09/04/2025	38081	0.307			
09/05/2025	36693	0.289	0.89		1.27
09/06/2025	39426	2.442			
09/07/2025	38396	0.377			
09/08/2025	39160	0.606	0.66		0.84

09/09/2025	59095	0.945			
09/10/2025	48083	0.316	0.79		0.95
09/11/2025	36104	0.536			
09/12/2025	38589	0.499	0.8		1.19
09/13/2025	45037	0.475			
09/14/2025	39591	0.505			
09/15/2025	49006	0.466	0.86		0.98
09/16/2025	59603	0.338			
09/17/2025	36929	0.289	0.92		0.8
09/18/2025	36976	0.426			
09/19/2025	37347	0.313	0.94		0.84
09/20/2025	39736	0.319			
09/21/2025	41412	0.609			
09/22/2025	41627	0.518	0.73		1.41
09/23/2025	37856	1.287			
09/24/2025	62235	0.722	0.61		0.87
09/25/2025	40916	0.356			
09/26/2025	36044	0.594	0.68		1.13
09/27/2025	37777	0.328			
09/28/2025	37825	0.509			
09/29/2025	39106	0.173	0.82		1.04
09/30/2025	53671	0.854			