



**DEPARTMENT OF HEALTH**

Department of Health  
Division of Health Promotion and Disease Prevention (phone) 802-863-7341  
Office of Oral Health (fax) 802-651-1634  
108 Cherry Street, PO Box 70  
Burlington, Vt 05402-0070  
[www.healthvermont.gov](http://www.healthvermont.gov)

Helen Miller  
Jericho Underhill Water District  
401 VT. Rte. 15  
Underhill, Vt. 05489

Dear Helen,

Below are your results from the recent lab samples submitted to the Department of Health Laboratory compared to your field.

Date	Field results	Lab results	Difference
04/01/2011	0.60 ppm	0.29 ppm	0.31 ppm
04/08/2011	0.60 ppm	0.26 ppm	0.34 ppm
04/15/2011	0.50 ppm	0.25 ppm	0.25 ppm
04/22/2011	0.60 ppm	0.24 ppm	0.36 ppm
04/29/2011	0.60 ppm	0.25 ppm	0.30 ppm

Split Average: field: 0.58 ppm lab: 0.26 ppm  
~~April monthly average: 0.55 ppm~~  
High: 0.70 ppm  
Low: 0.40 ppm

Thank you for your continued interest in water fluoridation for your community.

Sincerely yours,

Linda Greaves, RDH  
Fluoridation Program  
Office of Oral Health  
PO Box 70, Drawer 38  
Burlington, Vt 05402  
802-651-1635