

**Results Report**State Health Dept # : 17-WB-01810  
Report Status : Final  
Date Report Released : 09/18/2017Report To Jericho Underhill Water  
ATTN OF Marc Maheux  
Address PO Box 174  
  
Underhill, VT 05489WSID VT0005096  
Account Name Jericho Underhill Water  
Date Received 09/15/2017  
Time Received 09:56  
Approved Date 09/18/2017

Sample Desc.	KIT AA	Sample Type	Routine/Comp
Collection Date	09/15/2017	Free Chlorine Residual	0.01 mg/L
Collection Time	05:00	Total Chlorine Residual	
Sampled By	Marc Maheux	Chlorinated?	Yes
Sampling Location	Kitchen sink	Field Temp.	
Street Address	38 Poker Hill	Field Fluoride	
Town	Underhill	Temp at Receipt	
Sampler's Comments			

**Test Enzyme Substrate Test**

Date/Time of Analysis 09/16/2017 13:30

Test Method SM20 9223B

Analyte	Result
Total Coliform	Detected
E.coli	Not detected

**Units of Measurement and Definitions:**

mL = milliliter, &gt; equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit, TNTC = Too Numerous To Count


The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:



Mary Celotti, Laboratory Director

*If you have received this report in error or have questions about this report, please call the laboratory at (802) 338-4724.*