



Department of Health
Division of Health Improvement
Office of Oral Health
108 Cherry Street - PO Box 70
Burlington, VT 05402-0070
www.HealthyVermonters.info

Agency of Human Services

[phone] 802-863-7341
[fax] 802-951-1218

March 13, 2006

Marc Mahieux
~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Dear *mar* ~~Mrs. Miller~~:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
12/23/05	1.2	1.0
01/06/06	1.2	0.9
01/13/06	1.2	0.9
01/20/06	1.2	0.9
01/27/06	1.3	0.9
02/03/06	1.1	0.9
02/10/06	1.2	0.9
02/17/06	1.3	1.0
02/24/06	1.3	1.0

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund
Alida I. Lund
Fluoridation Technician



VERMONT

Department of Health
Division of Health Improvement
Office of Oral Health
108 Cherry Street - PO Box 70
Burlington, VT 05402-0070
www.HealthyVermonters.info

Agency of Human Services

[phone] 802-863-7341
[fax] 802-951-1218

March 9, 2006

marc makeux

~~Helen Miller~~
Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

marc

Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
09/23/05	1.0	0.8
09/30/05	1.1	0.9
10/07/05	1.1	1.0
10/14/05	1.2	0.9
10/21/05	1.1	0.9
10/28/05	1.1	0.9
11/11/05	1.1	0.9
11/14/05	1.1	0.9
11/18/05	1.1	0.9
11/25/05	1.0	0.8
12/02/05	1.1	0.8
12/09/05	1.1	0.8
12/16/05	1.1	0.9
12/30/05	1.1	0.9

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician