

Results Report

State Health Dept # : 15-IB-00214

Report To Jericho Underhill Water
ATTN OF Marc Maheux
Address PO Box 174

Underhill, VT 05489

WSID VT0005096
Account Name Jericho Underhill Water
Date Received 06/24/2015
Time Received 11:01
Approved Date 06/30/2015

Sample Desc. KIT IB - Lead/Copper
Collection Date 06/24/2015
Collection Time 05:30
Sampled By Glenn Woytowich
Sampling Location Kitchen Sink
Street Address 35 Valleys Edge
Town Jericho

Sample Type
Free Chlorine Residual
Total Chlorine Residual
Chlorinated?
Field Temp.
Field Fluoride
Temp at Receipt

Test Metals by ICPMS

Date/Time of Analysis 06/29/2015 13:12
Test Method: EPA 200.8 IB

Analyte	Final Result	Units	Limit
Copper	0.16	mg/L	1.3 AL
Lead	<0.001	mg/L	0.015 AL

Units of Measurement and Definitions:

mg/L = Milligrams per liter or ppm (parts per million) ug/L = Micrograms per liter or ppb (parts per billion) < = less than TON = Threshold Odor Number
MCL = Maximum Contaminant Level SMCL = Secondary Maximum Contaminant Level MRDL = Maximum Residual Disinfectant Level
VHA = Vermont Health Advisory VMCL = Vermont Maximum Contaminant Level NLE = No Limit Established
AL (Action Level) = Level at or above which a water treatment action is determined for public water supplies and should be considered for private supplies.

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise.


Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont

Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:



Mary Celotti, Laboratory Director

***If you have received this report in error or if you have questions about this report,
please call the laboratory at (802) 863-7336.***