



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

August 8, 2001

Marc Mayhew
~~Helen Miller~~

Jericho/Underhill Water District
406 VT. Rte. 15
Underhill VT 05489

Marc
Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
06/29/01	1.3	1.1
07/06/01	1.2	1.1
07/13/01	1.3	1.0
07/20/01	1.2	1.0
07/27/01	1.2	1.1

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida Lund

Alida I. Lund
Fluoridation Technician