



Vermont Department of Health
Division of Health Improvement
Dental Health Services

Agency of Human Services

November 5, 2003

Marc Mahoney

~~Helen Miller~~

Jericho/Underhill Water District

406 VT. Rte. 15

Underhill VT 05489

Marc

Dear ~~Mrs.~~ Miller:

Below are listed the results reported by the Department of Health Laboratory on the recent samples of the Jericho/Underhill Water District water samples submitted.

DATE	FIELD RESULT (PPM)	LAB RESULT (PPM)
09/05/03	1.1	1.0
09/12/03	1.1	1.0
09/19/03	1.0	1.0
09/26/03	1.1	1.0
10/03/03	0.9	1.0
10/10/03	1.0	1.1
10/17/03	1.1	1.2
10/24/03	1.1	1.1

To provide on-going dental benefits, the optimal fluoride level should be maintained at 1.1 ppm. A range between 1.0 and 1.6 ppm is acceptable.

Thank you for your continued interest and cooperation.

Sincerely yours,

Alida I. Lund

Alida I. Lund

Fluoridation Technician