



LABORATORY REPORT

EPA 524.2

CLIENT: Jericho Underhill Water
PROJECT: WSID #5096
SITE: Poker Hill Tank
DATE RECEIVED: August 26, 2005
REPORT DATE: September 7, 2005
ANALYSIS DATE: September 2, 2005

ORDER ID: 39539
REFERENCE NUMBER: 258819
DATE SAMPLED: August 25, 2005
TIME SAMPLED: 8:00 PM
SAMPLER: MM
ANALYST: 725

<u>Parameter</u>	<u>Result</u> <u>ug/L</u>	<u>Parameter</u>	<u>Result</u> <u>ug/L</u>
Benzene	< 0.5	Isopropylbenzene	< 0.5
Bromobenzene	< 0.5	4-Isopropyltoluene	< 0.5
Bromomethane	< 0.5	Naphthalene	< 1.0
Bromochloromethane	< 0.5	MTBE	< 1.0
n-Butylbenzene	< 0.5	n-Propylbenzene	2.2
sec-Butylbenzene	< 0.5	Styrene	< 0.5
tert-Butylbenzene	< 0.5	1,1,1,2-Tetrachloroethane	< 0.5
Carbon tetrachloride	< 0.5	1,1,2,2-Tetrachloroethane	< 1.0
Chlorobenzene	< 0.5	Tetrachloroethene	< 0.5
Chloroethane	< 0.5	Toluene	< 0.5
Chloromethane	< 0.5	1,2,3-Trichlorobenzene	< 0.5
2-Chlorotoluene	< 0.5	1,2,4-Trichlorobenzene	< 0.5
4-Chlorotoluene	< 0.5	1,1,1-Trichloroethane	< 0.5
Dibromomethane	< 1.0	1,1,2-Trichloroethane	< 0.5
Dichloromethane	< 3.0	Trichloroethene	< 0.5
1,2-Dichlorobenzene	< 0.5	Trichlorofluoromethane	< 1.0
1,3-Dichlorobenzene	< 0.5	1,2,3-Trichloropropane	< 0.5
1,4-Dichlorobenzene	< 0.5	1,2,4-Trimethylbenzene	19.3
1,1-Dichloroethane	< 0.5	1,3,5-Trimethylbenzene	5.0
1,2-Dichloroethane	< 0.5	Vinyl Chloride	< 0.5
1,1-Dichloroethene	< 0.5	Xylenes, Total	2.5
cis-1,2-Dichloroethene	< 0.5	Bromodichloromethane	1.8
trans-1,2-Dichloroethene	< 0.5	Chloroform	4.4
1,2-Dichloropropane	< 0.5	Dibromochloromethane	0.9
1,3-Dichloropropane	< 0.5	Dichlorodifluoromethane	< 0.5
2,2-Dichloropropane	< 0.5	Bromoform	< 0.5
1,1-Dichloropropene	< 0.5	Total Trihalomethanes	7.1
cis-1,3-Dichloropropene	< 0.5	Surrogate 1	92.2%
trans-1,3-Dichloropropene	< 0.5	Surrogate 2	91.1%
Ethylbenzene	< 0.5	UIP's	> 10.
Hexachlorobutadiene	< 0.5		