



DEPARTMENT OF HEALTH

Department of Health
Division of Health Promotion and Disease Prevention
Office of Oral Health
108 Cherry Street, PO Box 70
Burlington, Vt 05402-0070
www.healthvermont.gov

(phone) 802-863-7341
(fax) 802-651-1634

Helen Miller
Jericho Underhill Water District
401 VT. Rte. 15
Underhill, Vt. 05489

Dear Helen,


Below are your results from the recent lab samples submitted to the Department of Health Laboratory compared to your field.

Date	Field results	Lab results	Difference
01/07/2011	0.90 ppm	0.90 ppm	0.00 ppm
01/14/2011	1.00 ppm	0.80 ppm	0.20 ppm
01/22/2011	0.90 ppm	0.80 ppm	0.10 ppm
01/28/2011	1.00 ppm	0.90 ppm	0.10 ppm

Split Average: field: 0.95 ppm lab: 0.85 ppm
January monthly average: 1.00 ppm
High: 1.20 ppm
Low: 0.90 ppm

Thank you for your continued interest in water fluoridation for your community.

Sincerely yours,


Linda Greaves, RDH
Fluoridation Program
Office of Oral Health
PO Box 70, Drawer 38
Burlington, Vt 05402
802-651-1635



DEPARTMENT OF HEALTH

Department of Health
Division of Health Promotion and Disease Prevention (phone) 802-863-7341
Office of Oral Health (fax) 802-651-1634
108 Cherry Street, PO Box 70
Burlington, Vt 05404-0070
www.healthvermont.gov

Helen Miller
Jericho Underhill Water District
408 VT. Rte. 15
Underhill, Vt. 05489

Dear Helen,


Below are your results from the recent lab samples submitted to the Department of Health Laboratory compared to your field.

Date	Field results	Lab results	Difference
02/04/2011	0.90 ppm	0.82 ppm	0.08 ppm
02/11/2011	0.80 ppm	0.80 ppm	0.00 ppm
02/18/2011	1.00 ppm	0.80 ppm	0.20 ppm
02/25/2011	0.90 ppm	0.70 ppm	0.20 ppm

Split average: field: 0.90 ppm lab: 0.78 ppm
February monthly average: 0.96 ppm
High: 1.10 ppm
Low: 0.80 ppm

Thank you for your continued interest in water fluoridation for your community.

Sincerely yours,


Linda Greaves, RDH
Fluoridation Program
Office of Oral Health
PO Box 70, Drawer 38
Burlington, Vt 05402
Phone: 802-651-1635
Fax: 802-651-1634
linda.greaves@ahs.state.vt.us