

VERMONT DEPARTMENT OF HEALTH LABORATORY
 359 SOUTH PARK DRIVE
 COLCHESTER, VT 05446
 (802) 338-4724 (800) 660-9997 (VT ONLY)

ANALYSIS of WATER for HALOACETIC ACIDS using Method 552.2 (GC/ECD)

LITS Number 2016003974-001-A

State Health Dept No. 17S00018

Kit Type Kit OK (haloacetic acids)

WSID# 0000005096

Kit Number

Address MARC MAHEUX
 JERICHO-UNDERHILL WATER
 38 POKER HILL RD
 PO BX 236
 UNDERHILL VT 05489

JERICHO-UNDERHILL WATER

Sampler Title

Purpose of Sample Compliance Monitor

Type of Sample

CHLORINE, FREE 0.04

CHLORINE, TOTAL

Field Temp (C) 16.7

Date/Time Received 08/04/2016 15:29:00

Date/Time of Sampling 08/04/2016 13:00:00

Report Status Final

Sample Location 7 Park St/ 3 Bay Sink

Date Reported 08/11/2016

Town Underhill

Sample Number

Released By JPM

Collected By Marc Maheux

Haloacetic Acids	Result	Units	Limit
Chloroacetic Acid	< 0.001	mg/L	
Bromoacetic Acid	< 0.001	mg/L	
Dichloroacetic Acid	< 0.001	mg/L	
Trichloroacetic Acid	< 0.001	mg/L	
Dibromoacetic Acid	< 0.001	mg/L	
Total Haloacetic Acids	< 0.005	mg/L	Total HAA's 0.06 mg/L MCL

Comments:

Test Note: Sample temperature at time of receipt was greater than approved method preservation requirements.

Registry Comments:

Definitions: < = Less than > = Greater than MCL=Maximum Contaminant Level VHA=Vermont Health Advisory
 mg/L = milligrams per liter or PPM (parts per million) ug/L = micrograms per liter or PPB (parts per billion)

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320. Results relate only to the items tested.

This report shall not be reproduced, except in full, without the written approval of the laboratory.